

# SINTEF Product Certificate

## No. 3566

Issued: 12.09.2019

Renewed: 13.09.2024

Valid until: 01.10.2029

Provided listed on

[www.sintefcertification.no](http://www.sintefcertification.no)

SINTEF confirms that

## Jets DC Pipe Interrupter for use in Vacuum Systems

complies with the requirements in

› **EN 14453 (\*)**

### Certificate holder

Jets Vacuum AS  
Myravegen 1  
6060 Hareid  
Norway

### Manufacturer

Jets Vacuum AS  
Myravegen 1  
6060 Hareid  
Norway

### Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

### Product description

Jets DC Pipe Interrupter for use in Vacuum Systems is a device to prevent pollution by back-flow of potable water. When used as intended, the product can be used for category 5 liquids in accordance with EN 1717.

### Performance requirements in TEK

#### *Working pressure*

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

#### *Back-flow*

The product has protection against back-flow and entering of polluted liquids.

### Other requirements

#### *Marking*

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.



Anne-Jorunn Enstad  
Certification Manager