

Notified body no. 1071
SINTEF
P.O.Box 124 Blindern – NO-0314 Oslo

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1071- CPR – 1709

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Protan SK Wall Covering

(The product is classified in the reaction to fire class (Euroclass) C-s2, d0 according to EN 13501-1:2018.

The classification is valid on a substrate of gypsum plasterboard (paper faced) and all substrates with class A1 or A2 with thickness ≥ 6 mm and density ≥ 600 kg/m³)

produced by
Protan AS
P.O. Box 420
N-3002 Drammen, Norway

and produced in the manufacturing plant
Protan AS
Baches vei 1
3413 Lier, Norway

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

NS-EN 15102:2007+A1:2011

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 05.01.2012 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, and latest on 01.11.2027, provided the certificate is listed on www.sintefcertification.no.

Oslo, 28.04.2023



.....
Anne-Jorunn Enstad
Certification Manager