

# SINTEF Product Certificate

## No. 3139

Issued: 30.04.2015  
Revised: 26.02.2025  
Valid until: 01.03.2030  
Provided listed on  
[www.sintefcertification.no](http://www.sintefcertification.no)

SINTEF confirms that

## Resideo Braukmann RV260 check valves

complies with the requirements in

› **EN 13959**



### Certificate holder

Pittway Sàrl  
A3 - ZA La Pièce 6  
1180 Rolle  
Switzerland

### Manufacturer

Ademco 1 GmbH  
Hardhofweg 40  
74821 Mosbach  
Germany

### Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

### Product description

Resideo Braukmann RV260 check valves in DZR brass.

The following models are included:

- › RV260-1/2LFA – DN15
- › RV260-3/4LFA – DN20
- › RV260-1LFA – DN25
- › RV260-11/4LFA – DN32
- › RV260-11/2LFA – DN40
- › RV260-2LFA – DN50

### Performance requirements in TEK

#### *Working pressure*

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

#### *Effect on drinking water*

The product does not submit substances which reduce drinking water quality or cause danger to health.

#### *Back-flow*

The product has protection against back-flow and entering of polluted liquids.

### Other requirements

#### *Marking*

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.

#### *Dezincification resistance*

The product has been tested for dezincification resistance according to EN ISO 6509.



Monica Strøm Nodland  
Certification Manager

