

SINTEF Product Certificate

No. 3139

Issued: 30.04.2015

Revised: 11.07.2023

Valid until: 01.05.2025

Provided listed on

www.sintefcertification.no

SINTEF confirms that

Resideo Braukmann RV260 check valves

complies with the requirements in

› **EN 13959**



Certificate holder

Pittway Sàrl
A3 - ZA La Pièce 6
1180 Rolle
Switzerland

Manufacturer

Ademco 1 GmbH
Hardhofweg 40
74821 Mosbach
Germany

Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

Product description

Resideo Braukmann RV260 check valves in DZR brass.

The following models are included:

- › RV260-1/2LFA – DN15
- › RV260-3/4LFA – DN20
- › RV260-1LFA – DN25
- › RV260-11/4LFA – DN32
- › RV260-11/2LFA – DN40
- › RV260-2LFA – DN50

Performance requirements in TEK

Working pressure

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

Effect on drinking water

The product does not submit substances which reduce drinking water quality or cause danger to health.

Back-flow

The product has protection against back-flow and entering of polluted liquids.

Other requirements

Marking

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.

Dezincification resistance

The product has been tested for dezincification resistance according to EN ISO 6509.



Monica Strøm Nodland
Certification Manager

