

# SINTEF Product Certificate

## No. 3161

Issued: 01.07.2015

Revised: 11.07.2023

Valid until: 01.09.2025

Provided listed on

[www.sintefcertification.no](http://www.sintefcertification.no)

SINTEF confirms that

## Resideo Braukmann D06F-LFA and D06F-LFE pressure reducing valves

complies with the requirements in

- › EN 1567
- › NKB Product Rules no. 4
- › Elastomer Guideline (\*) and DVGW W 270 (\*)



### Certificate holder

Pittway Sàrl  
A3 - ZA La Pièce 6  
1180 Rolle  
Switzerland

### Manufacturer

Ademco 1 GmbH  
Hardhofweg 40  
74821 Mosbach  
Germany

### Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

### Product description

Resideo Braukmann D06F-LFA and D06F-LFE pressure reducing valves in DZR brass.

The following models are included:

- › D06F-1/2LFA and D06F-1/2LFE – DN15
- › D06F-3/4LFA and D06F-3/4LFE – DN20
- › D06F-1LFA and D06F-1LFE – DN25
- › D06F-1 1/4LFA and D06F-1 1/4LFE – DN32
- › D06F-1 1/2LFA and D06F-1 1/2LFE – DN40
- › D06F-2LFA and D06F-2LFE – DN50

### Performance requirements in TEK

#### Working pressure

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

#### Effect on drinking water

The product does not submit substances which reduce drinking water quality or cause danger to health.

The product has been tested for release of heavy metals to drinking water according to NKB Product Rules no. 4.

The product has been tested for releases to drinking water according to Elastomer Guideline

### Other requirements

#### Marking

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.

#### Dezincification resistance

The product has been tested for dezincification resistance according to EN ISO 6509.



Monica Strøm Nodland  
Certification Manager

