

SINTEF Product Certificate

No. 4086

Issued: 03.06.2026

Valid until: 01.07.2031

Provided listed on

www.sintefcertification.no

SINTEF confirms that

Sanipex PrevPEX pipe

complies with the requirements in

- › EN ISO 15875-2
- › EN ISO 15875-5



Certificate holder

Georg Fischer JRG AG
Hauptstraße 130
4450 Sissach, Switzerland

Manufacturer

The product is produced at factory 1286 in Sweden,
as specified in the evaluation report dated 27.05.2026.

Factory production control

The manufacturing of the product is subject to factory
production control in accordance with the provisions in
EN ISO/IEC 17065.

Product description

Sanipex PrevPEX pipe, type PE-Xa, for use in low-pressure
water mist systems. The pipe shall be used together with
Sanipex fittings for PE-Xa pipes, as specified in SINTEF
Product Certificate No. 0049.

The following dimensions are included:

- › 16 × 1.5 mm
- › 20 × 1.9 mm

Performance requirements in TEK

Working pressure

The product is capable of meeting the intended perfor-
mance requirements under normal operating pressure.

Sanipex PrevPEX pipe has the following key product prop-
erties:

- › Maximum operating pressure: 1.6 MPa (16 bar)
- › Maximum permissible temperature for short periods
(< 1 month): 50 °C
- › Maximum permissible continuous operating tempera-
ture: 35 °C

Other requirements

Marking

The product may be marked with the SINTEF certification
mark as shown above. The mark may also be used on
packaging and marketing materials concerning the certi-
fied product.



Anne-Jorunn Enstad
Certification Manager



SINTEF Certification

www.sintefcertification.no

info@sintefcertification.no

P.O.Box 124 Blindern, NO-0314 Oslo

Standards marked with an asterisk (*) are
not included in SINTEFs accreditation

Mal PSse san versjon 05.02.2026

SINTEF AS

by its institute SINTEF Community

www.sintef.no

Enterprise register: NO 919 303 808 MVA