

Notified body no. 1071
SINTEF
P.O.Box 124 Blindern – NO-0314 Oslo

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1071- CPR – 3071

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Huntonit Brannit

Reaction to fire class B-s1,d0, according EN 13501-1:2007+A1:2009

Huntonit Brannit, wood fibre panels painted with fire retardant paint, nominal thickness = 11.0 mm, nominal density = 818 kg/m³ meet, the requirements for general purpose boards for use in dry conditions, technical class MBH according to EN 622-1: 2003, Table 1 and 2, and EN 622-3: 2004, Table 2.

Reaction to fire classification is valid for the following end use conditions:

- Substrate of Euroclasses A1 or A2-s1,d0 with thickness ≥ 11 mm having a density ≥ 525 kg/m³
- Mechanically fixing with horizontal or vertical joints in accordance with manufacturers installation instruction
- The product can be installed with or without, ventilated or not ventilated, air gap

**produced by
Byggma ASA**

P.O.Box 21
NO-4701 Vennesla, Norway

**in the manufacturing plant
Huntonit AS**

Venneslavegen 233
NO-4700 Vennesla, Norway

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 13986:2004+A1:2015

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 01.12.2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, and latest on 01.02.2025, provided the certificate is listed on www.sintefcertification.no.

Oslo, 25.01.2022



.....
Anne-Jorunn Enstad
Certification Manager